

Serial No.
28576

MOBILE CATERING VEHICLE/TRAILER SAFETY CHECK

NEXT SAFETY
CHECK DUE WITHIN
6-12 MONTHS



This safety check is for gas safety purposes only in accordance with The Gas Safety (Installation and Use) Regulations.

Registered Business Details REGISTRATION NO. 224056

Gas operative John Lottens (Print name)

Operative licence No. 3168880

Company Connors

Address 23 Ashburn Drive
Darlington
Widnesbury

Postcode WS0 Tel No. 0727170880

Details of Vehicle Trailer (tick appropriate box)

Reg No. or Serial/Chassis No. UNCR74D

LPG cylinder housing satisfactory Yes/No ✓

Fire extinguisher(s) provided Yes/No ✓

Fire blanket provided Yes/No/NA ✓

Current safety certificate displayed Yes/No ✓

Safe use of LPG information displayed Yes/No ✓

Vehicle/Trailer Owner Details

Name (Mr/Mrs/Miss/Ms) TROGHERBERT

Address 24 FAIR ACRES COVENTRY RD
LUTTERWORTH

Postcode LE174FA Tel No. 07583033836

No. of appliances tested 1

APPLIANCE DETAILS

	Appliance type	Make	Model	Serial No.	Flue type OF/RS/FL	Is appliance secure Yes/No	Is appliance isolation valve fitted Yes/No
1	Four burner	Wester	Wester		FL	Y	Y
2							
3							
4							

INSPECTION DETAILS

	Operating pressure in mbar or heat input kW or Btu/h	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of flue satisfactory Yes/No/NA	Flue termination satisfactory Yes/No/NA	Flue flow check Pass/Fail/NA	Spillage check Pass/Fail/NA	Appliance serviced Yes/No	Appliance safe to use Yes/No
1	36mbar	Y	Y	✓	✓	✓	✓	NO	Y
2									
3									
4									

DEFECT(S) IDENTIFIED

	If Warning/Advice Notice issued insert serial No.*
1	
2	
3	
4	

Cylinder/final connection hoses to installation satisfactory Yes/No ✓

Gas installation pipework (visual inspection) satisfactory Yes/No ✓

Gas tightness test satisfactory Yes/No/NA ✓

ECV accessible and operable Yes/No ✓

LPG regulator operating pressure (mbar) 36mbar

LPG regulator lock-up pressure (mbar) 55mbar

REMEDIAL ACTION TAKEN

1	
2	
3	
4	

Safety check issued by: Signed [Signature]

Print name: J. LOTTENS

Received by: [Signature]

Date appliance(s)/flue(s) checked: 16-4-13

Copyright © CORGidirect April 2012. The format and layout of this document may not be reproduced in any form without prior written consent.

Gas Safe is a registered trade mark of the HSE and is used under licence.